

Contact person RISE
Lars Erlandson
Energy and circular economy
+46 10 516 58 05
lars.erlandson@ri.se

Date
2017-06-08

Reference
7F012919

Page
1 (4)

Logstor Polska Sp. zo.o.
ul Handlowa 1
Mikulczyce
PL-41-807 Zabrze
Poland

Annual inspection for EHP-approval

Manufacturer: Logstor Polska Sp. zo.o., Zory
Product: District heating pipes, OPTI production
Standard: EN 253:2009+A2:2015 and EN 15698-1:2009
Certification rules: Euroheat & Power EHP/001, January 2016
Certificate: 01/10
Agreement: 210-04-0347
Date of inspection: 2017-05-17
Manufacturer's representative: Beata Bondaruk

Manufacturer Quality Certificate: ISO 9001:2008

At the inspection visit the manufacturer's quality plan and quality surveillance resources were examined in respect of the requirements laid down in EN 253:2009+A2:2015 and EN 15698-1:2009 and in the Euroheat & Power Certification Guidelines EHP/001, January 2016. The examination also included the extent and results of the manufacturer's internal quality surveillance activities directed towards the products in question.

The tables below summarise the results of the assessments performed. The corresponding clause in EN 253:2009+A2:2015 and EN 448:2009 are given as reference.

Service pipe, EN 253:2009+A2:2015

Clause	Characteristic	Manufacturer's reference doc.	Judgment of documentation, resources and results
4.2.1	Make, marking delivery specification	GITP 300-01	No remarks
4.2.2 4.2.3	Dimensions	GITP 300-01	No remarks
4.2.4	Finish, surface, etc	GITP 300-01	No remarks

RISE Research Institutes of Sweden AB

Postal address
Box 24036
SE-400 22
GÖTEBORG
Sweden

Office location
Gibraltargatan 35
SE-412 79
GÖTEBORG

Phone / Fax / E-mail
+46 10 516 50 00
+46 33 13 55 02
info@rise

This document may not be reproduced other than in full, except with the prior written approval of RISE.



Casing pipe, EN 253:2009+A2:2015

Clause	Characteristic	Manufacturer's reference doc.	Judgment of documentation, resources and results
4.3.1	Material	GITP 300-01	No remarks
4.3.1.1	Carbon black dispersion	Certificates	No remarks
4.3.1.3	Thermal stability	GITP 314-01 11	No remarks
4.3.1.4	Use of rework material	GITP 314-01 11	No remarks
4.3.2.1 4.3.2.2	Diameter Wall thickness	GITP 314-01 14	No remarks
4.3.2.3	Appearance and surface finish	GITP 314-01 14	No remarks
4.3.2.4	Elongation at break	GITP 314-01 15	No remarks
4.3.2.6	Stress crack resistance	GITP 314-01 15	No remarks

Polyurethane foam insulation, EN 253:2009+A2:2015

Clause	Characteristic	Manufacturer's reference doc.	Judgment of documentation, resources and results
4.4.1	Composition Make, marking and delivery specifications	GITP 314-01 4	No remarks
4.4.2	Cell structure - Cell size	GITP 314-01 15	No remarks
4.4.2	Cell structure – Closed cell content	-	No remarks
4.4.2	Cell structure – Voids and bubbles	GITP 314-01 15	No remarks
4.4.3	Compressive strength	GITP 314-01 15	No remarks
4.4.4	Density	GITP 314-01 10	No remarks
4.4.5	Water absorption	GITP 314-01 15	No remarks

Pipe assembly
Single pipe EN 253:2009+A2:2015

Clause	Characteristic	Manufacturer's reference doc.	Judgment of documentation, resources and results
4.5.2 and 4.5.3	Dimension of pipe ends and outside diameter	GITP 314-01 14	No remarks
4.5.4	Centre line deviation	GITP 314-01 15	No remarks
4.5.11	Measuring wires EN 14419:2009	GITP 314-01 10	No remarks

Twin pipe, EN 15698-1:2009

Clause	Characteristic	Manufacturer's reference doc.	Judgment of documentation, resources and results
4.5.1	End alignment of forward and return service pipes	GITP 314-01 10	No remarks
4.5.2	Distance between forward and return service pipes	GITP 314-01 10	No remarks
4.5.3	Twisting of service pipes	GITP 314-01 10	No remarks

Conclusion

The manufacturer's Quality Plan and quality surveillance resources, activities and results fulfil the requirements specified in Euroheat & Power EHP/001, January 2016.

RISE Research Institutes of Sweden AB
Energy and circular economy - Pipe Centre

Performed by:

Lars Erlandson

Signed by: Lars Erlandson
 Date & Time: 2017-06-08 08:36:23 +0200

Lars Erlandson

RISE Research Institutes of Sweden AB



Gamybos skyriaus
 viršininkas
 Raimundas Gudukas

Raimundas Gudukas