



CERTIFICATE FI 28632 A2

Our Ref. 276986-1

Product Fitting for overhead lines

Type SO115

Trade mark ENSTO

Certificate Holder Ensto Finland Oy
Ensio Miettisen katu 2
FI-06150 PORVOO, FINLAND

Manufacturer Ensto Finland Oy
Ensto Utility Networks
Ensio Miettisen katu 2
FI-06150 PORVOO, FINLAND

Technical information Helical tie for covered conductors

Type	Color code	Covered conductors [mm ²]	Insulator neck diameter [mm]
SO115.9585	Blue	70 / 95 / 99	73 - 85
SO115.150	White	120 / 150 / 157	73 - 85
SO115.5085	Red	35 / 50 / 62	73 - 85

The product is certified according to the following standard(s) EN 50397-2:2009

Validity This certificate is valid until 30 June 2019 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

Date of issue 06 March 2018

SGS Fimko Ltd

Signature

Sixten Lökfors
Project Manager

This certificate has 1 appendix




This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 28632 A2

Manufacturing site

Ensto Ensek AS
Paldiski mnt. 35 / 4A
EE-76606 KEILA, ESTONIA

Additional information



Ensto Finland test reports:
2915S, 2913S, 2914S, 2699S, 2909S, 2911S, 2962, 2963 and 2964

Slip test in low temperature was performed in temperature -25 ± 3 °C.

This certificate replaces Certificate FI 28632 A1 dated 16 January 2015,
due to added Additional information.